



Dip Specification

Equipment or Coils as indicated shall be corrosion protected by Bronz-Glow. Bronz-Glow shall issue a “**Certificate of Coating Compliance**” to verify that the specification has been met as part of the closing documentation. An “**Owner’s Coated Coil Cleaning Maintenance Program**” shall be available for close out documentation and upon project completion.

Condenser, evaporator, water, steam or any other type of heat transfer coil, shall be coated using Bronz-Glow’s Husky Coil Coat **dip application** process for corrosion protection. Coil coating material and process shall have passed a minimum of 6,000 hour salt spray test in accordance with ASTM Standard B117.85. Coil film coating shall be effective in pH range of 1-14. Product shall be a complex chain linked polyelastomer material with properties including 4,000 PSI tensile strength and 250% flexibility. Bronz-Glow’s coating shall have a 10 year Florida UV inhibitor added. Coating should be field repairable, and touch-up material available in aerosol form. Field coating is not acceptable. No substitutes allowed.

Acceptable Products; Husky Coil Coat

Cabinet Coating if Required.

All cabinet components shall be coated with SPC. Coating shall be clear or colored and shall protect in pH ranges of 1.0-14.0, have 250% elasticity, 250% flexibility, and passed ASTM Salt Spray test B117.85 for 2,000 hours.

Acceptable Products: SPC clear or SPC tinted

.....

Coated coils shall be warranted for 60 Months under Bronz-Glow’s WP-1 Coil Coating Warranty. Cabinets shall be warranted under Bronz-Glow’s WP-24 Cabinet Coating Warranty. No other warranty is implied. A copy of this warranty is available upon request to the owner. Call for pricing and details.

POC: Bronz-Glow Technologies, Inc.
Ph: (800) 555-6385
Fax: (904) 825-0122
Customerserv@Bronz-Glow.com
<http://www.Bronz-Glow.com>