

CONFIDENTIAL

YORK
INTERNATIONAL

February 8, 1993

Mr. Robert Haydu
Bronz-Glow Coatings Corporation
1850 Wambolt Street
Jacksonville, Florida 32202

Dear Robert,

As I promised in August of 1991 when I was embarking on this salt spray evaluation program, I am providing you with the result of the testing as they pertain to your product. As you know, I also evaluated coatings from other vendors for comparison but will limit this report only to the performance of your coating. Testing has been concluded and the following illustrates how your coating performed.

The test was based on ASTM B117.85. The test consisted of continuous exposure of the coated coils to 5% salt solution at 95 degree F for 6,300 hours (37.5 weeks). The initial test duration was set at 3,000 hours at the end of which the test would have been terminated. Testing of your coating, at your request, went beyond this target stop period.

The coated coils were of one, two and three row enhanced fin coils with 16 fins per inch. The fins were made from 0.0047 aluminum material, the hairpins were made from .012 wall rifled tubing, and the endsheets were made from galvanized steel.

After 6,300 hours of evaluation, the series 100 Husky coat demonstrated excellent resistance to general and galvanic corrosion, except for bubbles formed on the endsheets.

Please be placed on notice that, pursuant to our mutual understanding at the outset of these tests, we are providing you with the confidential test results pertaining to your product. This transmittal was agreed to as a courtesy to your organization, so that you may be able to learn from our experiences. There was never any intent nor discussion by CES/York or Bronz-Glow concerning any use of these results other than for internal review and analysis by Bronz-Glow. We would hope that your organization honors this agreement and that nothing concerning these tests is disclosed to the public or to the industry.

Central Environmental Section
York International Corporation
5005 Interstate Drive North
Norman, Oklahoma 73069
Telephone: (405) 833-1111

CONFIDENTIAL

Test Result
2/8/93
Page 2

YORK
INTERNATIONAL

Prior to any disclosure or use, we would expect to be provided with adequate details on the nature of the disclosure, so that we may be able to review it and provide our approval. No disclosure shall occur without prior receipt of the written approval of CES/York.

Best Regards,

Chuck [REDACTED]
MFG. ENGR.

cc: [REDACTED]
[REDACTED]
[REDACTED]

Central Environmental Systems
York International Corporation
5005 Interstate Drive North
Norman, Oklahoma 73069
Telephone (405) 262-1111